

Attestation of Conformity

No. N8AUK 072071 0027 Rev. 00

Holder of Certificate: **SOLARWATT GmbH**
Maria-Reiche-Str. 2a
01109 Dresden
GERMANY

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulations and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062202038-00

Date, 2022-11-29



(David Bo)

Page 1 of 2

After preparation of the necessary UK regulation technical documentation as well as the UK declaration of conformity the required UKCA marking can be affixed on the product. Other applicable UK regulations have to be observed.

Attestation of Conformity

No. N8AUK 072071 0027 Rev. 00

Model(s):

Eco 120M (xxx Wp), xxx=320-380 in step of 5
 Eco 60M style (xxx Wp), xxx=315-330 in steps of 5
 Eco 120M style (xxx Wp), xxx=345-380 in steps of 5
 SOLARWATT Panel classic H 1.1 (xxx Wp) style,
 xxx=345-360 in steps of 5
 SOLARWATT Panel classic H 1.2 (xxx Wp) style,
 xxx=365-380 in steps of 5
 SOLARWATT Panel classic H 1.1 (xxx Wp) pure,
 xxx=345-380 in steps of 5
 SOLARWATT Panel classic H 1.1 (xxx Wp) pure, low carbon,
 xxx=345-380 in steps of 5
 SOLARWATT Panel classic H 2.0 (xxx Wp) pure,
 xxx=380-415 in steps of 5
 SOLARWATT Panel classic H 2.0 (xxx Wp) black,
 xxx=380-415 in steps of 5
 SOLARWATT Panel classic AM 2.0 (xxx Wp) pure,
 xxx=380-415 in steps of 5
 SOLARWATT Panel classic AM 2.0 (xxx Wp) black,
 xxx=380-415 in steps of 5
 SOLARWATT Panel classic AM 2.0 (xxx Wp) pure, low carbon,
 xxx=380-415 in steps of 5
 xxx is standing for rated output power at STC

Parameters:

Fire Safety Class:	Class C according to UL790.
Safety Class:	Class II
Max. System Voltage:	1000V DC
Construction:	Framed, with Junction box, cable and connector.

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

After preparation of the necessary UK regulation technical documentation as well as the UK declaration of conformity the required UKCA marking can be affixed on the product. Other applicable UK regulations have to be observed.